

A tenant's guide to Smoke and Carbon Monoxide Detectors



Each of the smoke and carbon monoxide detectors should be tested every month. This can simply be done by pressing the test/hush button in the middle of the alarm for up to 10 seconds. The smoke detectors are interlinked, so testing one of the alarms should trigger the rest of the hardwired devices in the property. Carbon Monoxide (CO) alarms are separate from the smoke alarms. This is to help identify what has triggered the detectors.



Testing a smoke alarm



Testing a CO alarm

**NEVER REMOVE AN ALARM
WITHOUT LETTING ASHFIELD
DISTRICT COUNCIL KNOW.**



**Please report any issues to
Ashfield District Council immediately.**